

Laws, Rules & Wiring Standards of ND 2020 Errata's

1. 210.8 Ground-Fault Circuit-Interrupter Protection for Personnel. ... (F) **Outdoor Outlets.**

All outdoor outlets for dwellings, other than those covered in 210.8 (A)(3), Exception to (3), that are supplied by single-phase branch circuits rated 150 volts to ground or less, 50 amperes or less, shall have ground-fault circuit-interrupter protection for personnel. ~~This requirement shall become effective on January 1, 2023, for mini-split type heating/ventilating/air-conditioning (HVAC) equipment and other HVAC units employing power conversion equipment as a means to control compressor speed.~~

~~Informational Note: Power conversion equipment is the term used to describe the components used in HVAC equipment that is commonly referred to as a variable speed drive. The use of power conversion equipment to control compressor speed differs from multistage compressor speed control.~~

~~Exception **No. 1**: Ground-fault circuit-interrupter protection shall not be required on lighting outlets other than those covered in 210.8(C).~~

~~Exception **No. 2**: Ground-fault circuit-interrupter protection shall not be required for listed HVAC equipment. This exception shall expire September 1, 2026.~~

2. 24.1-06-03-01(7) Metal raceways or metal clad cable (type MC) rated for the environment shall be installed in:

d. Places of assembly

~~e. dormitories designed to house more than sixteen people. (requirement removed @ 1-27-21 board meeting)~~